



Phone: 503-554-8333
 1-855-554-8333 (TF)
 Mail: P.O. Box 699
 Newberg, OR 97132
 Email: info@hilandwater.com
 Internet: www.hilandwater.com

June 5, 2024

Otter Rock Water District Monthly Operations Report: June 2024

<https://diamondmaps.com/map.ashx?key=11003240705112957141>

June: Spring flow – June 2, 2024

Source	Flow rate
Spring 1 flow rate	30
Spring 2 flow rate	112
Spring 3 flow rate	45
Reservoir overflow rate	90

July. preview: Spring flow – July 1, 2024

Source	Flow rate
Spring 1 flow rate	30
Spring 2 flow rate	69
Spring 3 flow rate	41
Reservoir overflow rate	60

Chlorine levels

	First User	Distribution System
Average	0.30 ppm	0.24 ppm
High	0.50 ppm	0.30 ppm
Low	0.21 ppm	0.20 ppm

Other notable activities during the month:

1. 6/2 Meter read system.
2. 6/7 Updated meter reading sheets with install information.
3. 6/12 Collected Bac T Sample.
4. 6/13 Cody Marked a locate at 235 4th st
5. 6/14 Aaron purchased the parts for the next 16 meter installs
6. 6/14 Walter took extra time to clear brush away from the springs
7. 6/15 Completed consumer confidence report.
8. 6/25 Collected SOC Test.