



Phone: 503-554-8333
 1-855-554-8333 (TF)
 Mail: P.O. Box 699
 Newberg, OR 97132
 Email: info@hilandwater.com
 Internet: www.hilandwater.com

January 8th, 2024

Otter Rock Water District Monthly Operations Report: January 2025

January: Spring flow – January 1, 2025

Source	Flow rate
Spring 1 flow rate	30
Spring 2 flow rate	225
Spring 3 flow rate	50
Reservoir overflow rate	112.5

February. preview: Spring flow – February 1, 2025

Source	Flow rate
Spring 1 flow rate	50
Spring 2 flow rate	150
Spring 3 flow rate	30
Reservoir overflow rate	113

Chlorine levels

	First User	Distribution System
Average	0.36 ppm	0.36 ppm
High	0.51 ppm	0.48 ppm
Low	0.28 ppm	0.31 ppm

Other notable activities during the month:

1. 1/2 Meter Read system
2. 1/7 Collect Bac T Sample
3. 1/30 Continue prepping for meter splicing.
4. 1/30 Confirmed meter splice at 165 4th Street is not leaking