



Phone: 503-554-8333
1-855-554-8333 (TF)
Mail: P.O. Box 699
Newberg, OR 97132
Email: info@hilandwater.com
Internet: www.hilandwater.com

December 10th, 2024

Otter Rock Water District Monthly Operations Report: November 2024

November: Spring flow – November 1, 2024

Source	Flow rate
Spring 1 flow rate	23
Spring 2 flow rate	16
Spring 3 flow rate	30
Reservoir overflow rate	23

December. preview: Spring flow – December 1, 2024

Source	Flow rate
Spring 1 flow rate	36
Spring 2 flow rate	225
Spring 3 flow rate	45
Reservoir overflow rate	112.5

Chlorine levels

	First User	Distribution System
Average	0.32 ppm	0.28 ppm
High	0.59 ppm	0.34 ppm
Low	0.24 ppm	0.22 ppm

Other notable activities during the month:

1. 11/1 Meter Read system
2. 11/6 Excavate for meter splicing
3. 11/7 Excavate for meter splicing
4. 11/12 Investigate leak at 525 1st St. Found leak on customer side and shut off water.
5. 11/12 Bac T Sample